

CITY OF PARMA (PWS 3140089)
SOURCE WATER ASSESSMENT FINAL REPORT

January 7, 2002



State of Idaho
Department of Environmental Quality

Disclaimer: This publication has been developed as part of an informational service for the source water assessments of public water systems in Idaho and is based on data available at the time and the professional judgement of the staff. Although reasonable efforts have been made to present accurate information, no guarantees, including expressed or implied warranties of any kind, are made with respect to this publication by the State of Idaho or any of its agencies, employees, or agents, who also assume no legal responsibility for the accuracy of presentations, comments, or other information in this publication. The assessment is subject to modification if new data is produced.

Executive Summary

Under the Safe Drinking Water Act Amendments of 1996, all states are required by the U.S. Environmental Protection Agency to assess every source of public drinking water for its relative sensitivity to contaminants regulated by the Act. This assessment is based on a land use inventory of the designated assessment area and sensitivity factors associated with the wells and aquifer characteristics.

This report, *Source Water Assessment for City of Parma, Idaho*, describes the public drinking water system, the boundaries of the zones of water contribution, and the associated potential contaminant sources located within these boundaries. This assessment should be used as a planning tool, taken into account with local knowledge and concerns, to develop and implement appropriate protection measures for this source. **The results should not be used as an absolute measure of risk and they should not be used to undermine public confidence in the water system.**

The City of Parma drinking water system consists of five wells. In general, all of the City of Parma wells rate a moderate to low susceptibility to inorganic contaminants (IOCs), volatile organic contaminants (VOCs), synthetic organic contaminants (SOCs), and microbial contamination, except for the following issues. Well #7 does not have complete well log, which prevents confirmation of the low permeability layers that surround the other wells. In addition, information was lacking concerning the casing and annular seal depth. This lack of information causes Well #7 to have a high rating for hydrologic sensitivity as well as system construction, leading to an overall high susceptibility to IOCs, VOCs, SOCs, and microbial contaminants. Well #8 rates automatically high in susceptibility to all classes of contamination because Highway 20/26 passes within 50 feet of the wellhead.

The potential contaminant sources include a transportation corridor (Highway 20/26), automotive businesses, and agricultural land uses. Moderate to high hydrologic sensitivity and moderate to low system construction scores influenced the overall scores as well. Wells #6 and #9 had only a single potential contaminant source and Well #10 had no sources.

The IOCs fluoride and arsenic have been detected, but at levels below the current Maximum Contaminant Levels (MCLs) as set by the Environmental Protection Agency. Nitrate concentrations have been consistently below 0.5 parts per million (ppm), except in Well #6, which has had levels below 3.8 ppm. The MCL for nitrate is 10 ppm. Total coliform bacteria were detected in the distribution system in November 1992 and October 2000. Following the chlorination of the system, the VOC chloroform was detected in September 1993. Chloroform is a by-product of the chlorination process and is not considered a problem with the source water. Well #7 has recorded the presence of the SOC Di(2-ethylhexyl)phthalate at a level of 5.62 parts per billion (ppb) in November 1998. The MCL is 6.0 ppb. None of the other wells have recorded a detection of an SOC during any water chemistry tests. Though the drinking water system meets current regulations, the City of Parma should be aware that the potential for contamination still exists. Surrounding agricultural land use practices have contributed to putting all the wells within areas rated “high” for county level nitrogen fertilizer use, county level herbicide use, and total county level ag-chemical use.

This assessment should be used as a basis for determining appropriate new protection measures or re-evaluating existing protection efforts. No matter what ranking a source receives, protection is always important. Whether the source is currently located in a “pristine” area or an area with numerous

industrial and/or agricultural land uses that require surveillance, the way to ensure good water quality in the future is to act now to protect valuable water supply resources.

For the City of Parma, drinking water protection activities should first focus on maintaining the maintenance of the well seal, sanitary seal, and flood protection, as documented on sanitary surveys (an inspection conducted every five years with the purpose of determining the physical condition of a water system's components and its capacity). As many of the delineations cover predominantly urban areas, there should be a strong public education program to make people aware that they live above their source of drinking water. Storm water practices should also be assessed. Public education topics could include proper lawn and garden care practices, household hazardous waste disposal methods, proper care and maintenance of septic systems, and the importance of water conservation to name but a few.

Additionally, since some of the well delineations cross agricultural land uses and there should be a focus on the implementation of practices aimed at reducing the leaching of agricultural chemicals from agricultural land within the designated source water areas. No potential contaminant sources are allowed within 50 feet of any of the wellheads (IDAPA 58.01.08). Actions should be taken to protect the 50-foot boundary around Wells #7 and #8. Since it may be impractical to move Highway 20/26, a contingency plan should be set up to remove Well #8 from the system in the unlikely event a spill should occur near to the well. Much of the designated protection areas are outside the direct jurisdiction of the City of Parma, making collaboration and partnerships with state and local agencies and industry groups critical to the success of drinking water protection. All wells should maintain sanitary standards regarding wellhead protection. Should microbial contamination become a problem, appropriate disinfection practices would need to be implemented in a way to protect the drinking water from VOC by-products of the practice. If the system should need to expand in the future, new well sites should be located in areas with as few potential sources of contamination as possible, and the site should be reserved and protected for this specific use.

Due to the time involved with the movement of ground water, drinking water protection activities should be aimed at long-term management strategies even though these strategies may not yield results in the near term. A strong public education program should be a primary focus of any drinking water protection plan as the delineations contain some urban and residential land uses. There are multiple resources available to help communities implement protection programs, including the Drinking Water Academy of the U.S. Environmental Protection Agency. As there are major transportation corridors through the delineations, the Idaho Department of Transportation should be involved in protection activities. Drinking water protection activities for agriculture should be coordinated with the Idaho State Department of Agriculture, the Soil Conservation Commission, the local Soil Conservation District, and the Natural Resources Conservation Service.

A community must incorporate a variety of strategies in order to develop a comprehensive drinking water assessment protection plan, be they regulatory in nature (i.e. zoning, permitting) or non-regulatory in nature (i.e. good housekeeping, public education, specific best management practices). For assistance in developing protection strategies please contact the Boise Regional Office of the Idaho Department of Environmental Quality or the Idaho Rural Water Association.

SOURCE WATER ASSESSMENT FOR THE CITY OF PARMA, IDAHO

Section 1. Introduction - Basis for Assessment

The following sections contain information necessary to understand how and why this assessment was conducted. **It is important to review this information to understand what the ranking of this source means.** Maps showing the delineated source water assessment area and the inventory of significant potential sources of contamination identified within that area are attached (Appendix A). The lists of significant potential contaminant source categories and their rankings used to develop the assessment are also attached.

Background

Under the Safe Drinking Water Act Amendments of 1996, all states are required by the U.S. Environmental Protection Agency (EPA) to assess every source of public drinking water for its relative susceptibility to contaminants regulated by the Safe Drinking Water Act. This assessment is based on a land use inventory of the delineated assessment area and sensitivity factors associated with the wells and aquifer characteristics.

Level of Accuracy and Purpose of the Assessment

Since there are over 2,900 public water sources in Idaho, there is limited time and resources to accomplish the assessments. All assessments must be completed by May of 2003. An in-depth, site-specific investigation of each significant potential source of contamination is not possible. **Therefore, this assessment should be used as a planning tool, taken into account with local knowledge and concerns, to develop and implement appropriate protection measures for this source. The results should not be used as an absolute measure of risk and they should not be used to undermine public confidence in the water system.**

The ultimate goal of the assessment is to provide data to local communities to develop a protection strategy for their drinking water supply system. The Idaho Department of Environmental Quality (DEQ) recognizes that pollution prevention activities generally require less time and money to implement than treatment of a public water supply system once it has been contaminated. DEQ encourages communities to balance resource protection with economic growth and development. The decision as to the amount and types of information necessary to develop a source water protection program should be determined by the local community based on its own needs and limitations. Wellhead or source water protection is one facet of a comprehensive growth plan, and it can complement ongoing local planning efforts.

Section 2. Conducting the Assessment

General Description of the Source Water Quality

The public drinking water system for the City of Parma is comprised of five ground water wells that serve approximately 1,800 people through approximately 700 connections. The wells are located in Canyon County, generally on the northeast side of the City of Parma (Figure 1).

The most recent, significant water chemistry issue is the November 1998 Well #7 detection of the SOC Di(2-ethylhexyl)phthalate at a level of 5.62 ppb, where the MCL is 6.0 ppb. There have also been detections in the tested well water of the IOCs fluoride, arsenic, and nitrate at levels below the current MCLs as set by the EPA. Total coliform bacteria were detected in the distribution system in November 1992 and October 2000. Additionally, the VOC chloroform, a by-product of disinfection, was detected in all the wells. Other than Well #7, no SOCs have been detected in the well water. Surrounding agricultural land use practices have contributed to putting all the wells within areas rated “high” for county level nitrogen fertilizer use, county level herbicide use, and total county level ag-chemical use.

Defining the Zones of Contribution – Delineation


The delineation process establishes the physical area around a well that will become the focal point of the assessment. The process includes mapping the boundaries of the zone of contribution into time-of-travel (TOT) zones (zones indicating the number of years necessary for a particle of water to reach a well) for water in the aquifer. DEQ contracted with BARR Engineering to perform the delineations using a combination of MODFLOW and a refined analytical element computer model approved by the EPA in determining the 3-year (Zone 1B), 6-year (Zone 2), and 10-year (Zone 3) TOT for water associated with the Boise Valley aquifer in the vicinity of the City of Parma. The computer models used site specific data, assimilated by BARR Engineering from a variety of sources including the City of Parma well logs, other local area well logs, the Treasure Valley Hydrologic Project, and hydrogeologic reports (detailed below).

Treasure Valley Hydrologic Project Information (Petrich and Urban, 1996; Neely and Crockett, 1998; Petrich et al., 1999)

The “Treasure Valley” is a geopolitical region that includes the lower Boise River sub-basin. The lower Boise River sub-basin begins where the Boise River exits the mountains near the Lucky Peak Reservoir. From Lucky Peak Dam the lower Boise River flows about 64 (river) miles northwestward through the Treasure Valley to its confluence with the Snake River. The Treasure Valley Hydrologic Project area encompasses the lower Boise River area, and extends south to the Snake River. The southern area is included in the study area because of ground water flow from the Lower Boise River basin south toward the Snake River.

Significant amounts of desert area were converted to flood irrigated agriculture beginning in the 1860s. Irrigation led to increases in shallow ground water levels in some areas. The shallow groundwater levels provided an inexpensive and readily obtainable water supply that is used extensively throughout the valley. Much of the population growth in the Treasure Valley has been occurring in previously

FIGURE 1. Geographic Location of City of Parma



flood-irrigated agricultural areas, resulting in increased pumpage and a reduction in local aquifer recharge. In addition, irrigation in some areas has become more efficient, reducing the amount of irrigation-related infiltration. Decreasing aquifer recharge and increasing pumpage is thought to be contributing to decreasing ground water levels in some areas.

The Treasure Valley experiences a temperate and arid-to-semiarid climate. Average high temperatures range from about 90°F in summer to 36°F in winter; low temperatures range from about 20°F in winter to about 56°F in summer. The average precipitation ranges from about 8 to 14 inches throughout most of the valley, most of which falls during the colder months.

Major surface water bodies include the Boise River, Lake Lowell, and Lucky Peak Reservoir. The primary source of surface water in the Treasure Valley is precipitation falling in the high elevation area in the Boise River basin upstream of Lucky Peak Dam. Much of the runoff from high elevation areas is stored in three reservoirs: Anderson Ranch Reservoir, Arrowrock Reservoir, and Lucky Peak Reservoir.

The region's croplands are irrigated primarily with surface water through an extensive network of reservoirs and canals. The first canals were constructed in the 1860's; there are now over 1,100 miles of major and intermediate canals in the Treasure Valley. The primary sources of the irrigation water in the Treasure Valley include the Boise, Snake, and Payette Rivers. The majority of canals are owned and maintained by canal companies and irrigation districts.

HYDROGEOLOGY (FROM PETRICH ET AL., 1999)

The lower Boise River sub-basin (Treasure Valley) is located within the northwest-trending topographic depression known as the western Snake River Plain. The western Snake River Plain is a relatively flat lowland separating Cretaceous granitic mountains of west-central Idaho from the granitic/volcanic Owhyee mountains in southwestern Idaho. The western Snake River Plain extends from about Twin Falls, Idaho northwestward to Vale, Oregon. The Snake River Plain is about 30 miles wide in the section containing the lower Boise River.

Sediments originating from the surrounding mountains began accumulating on top of thick, basal basalts. Rifting and continued subsidence maintained the lowland topography, leading to the additional accumulation of water and sediments (Othberg, 1994). Basin infilling by sediments and basalt occurred from the late Miocene through the late Pliocene (Othberg, 1994). Incision caused by flowing water in major drainages (e.g., Snake and Boise Rivers) began in the late Pliocene or early Pleistocene, although deposition of coarse sediments continued during Quaternary glaciations (Othberg, 1994).

Several Quaternary basalt flows have been described in the western Snake River Plain, and have been assigned to the upper Snake River Group (Malde, 1991; Malde and Powers, 1962). Lava flowed across portions of the ancestral Snake River Valley (Malde, 1991) in an area that is now south of the Boise River. The Snake River then changed course, incising at its present location along the southern margin of the basalt flows. More recent eruptions (from Kuna Butte and other local sources) spilled lava into the canyon south of Melba. The Snake River has since incised this basalt (Malde, 1991).

The general stratigraphy of the western Snake River Plain consists of (from top to bottom) a thick layer of sedimentary deposits underlain by a thick series of basalt flows, which in turn are underlain by older, tuffaceous sediments and basalt (Malde, 1991; Clemens, 1993). The upper thick zone of

sediments (up to approximately 6,000 feet thick) distinguishes the western Snake River Plain from the eastern Snake River Plain, in which the upper section is primarily Quaternary basalt (Wood and Anderson, 1981).

The uppermost sediments and basalt belong to the Pleistocene-age Snake River Group. The Snake River Group consists of terrace sediments, Quaternary alluvium, and Pleistocene basalt flows (Wood and Anderson, 1981). Snake River Group sediments and basalts cover much of the project area (Othberg and Stanford, 1992).

The Snake River Group overlies the Idaho Group sediments. The Idaho Group sediments can be divided into two general parts (Wood and Anderson, 1981). The lower Idaho Group contains sediments described as lake and stream deposits of buff white, brown, and gray sand, silt, clay, diatomite, numerous thin beds of vitric ash, and some basaltic tuffs. The upper part of the lower Idaho Group also contains some local, thin, basalt flows. The upper Idaho Group consists of sands, claystones, and siltstones, but differs from the lower Idaho Group in that it contains a greater percentage of coarser-grained materials. The upper Idaho Group are associated with a fluvial/deltaic/lacustrine depositional environment; the lower Idaho Group sediments were deposited in more of a lacustrine/deltaic environment (Wood, 1994).

Wood (1994) identified a buried lacustrine delta within the Idaho Group sediments in the Parma-Caldwell area. The location of the delta in the middle of the western Snake River Plain suggests that the eastern part of the Boise River basin was delta plain and flood plain at the time of deposition, while the western part was a deep lake environment. The delta probably prograded northwestward into a lake basin 800 feet deep, based upon high resolution seismic reflection data and resistivity log interpretations. The delta-plain and front sediments were shown to be mostly fine-grained, well-sorted sand with thin layers of mud (Wood, 1994). The northwest trend of the delta indicates a sediment source to the southeast, such as where the Snake River flows today (Wood, 1994).

A substantial, laterally extensive layer of clay is found at depths of 300 to 700 feet below ground surface. The clay is important because it represents, in some areas, a significant aquitard separating shallow overlying aquifers from deeper zones. The clay, often described in well logs as having a blue or gray color, has been observed as far west as Parma, and as far east as Boise (although the clay is not found in the extreme eastern portions of the Treasure Valley). The clay varies from a few feet to a few hundred feet in thickness. Although significant layers of clay are present throughout the Idaho Group sediments, individual clay units are not necessarily continuous over large areas. Also, the top of the clay can vary in elevation by up to approximately 200 feet in some locations, such as in an area west of Lake Lowell. In general, sediments above the “blue clay” are coarser-grained than the interbedded sands, silts, and clays underlying the “blue clay.”

The top of the upper Idaho Group is marked in several parts of the Treasure Valley by a widespread fluvial gravel deposit known as the Tenmile Gravels. Tenmile Gravels contain rounded granitic rocks and felsic porphyries originating from the Idaho Batholith to the north and northeast. The Tenmile gravels range up to 500 feet in thickness along the Tenmile Ridge south of Boise, but are less than 50 feet thick in the Parma-Caldwell area (Wood and Anderson, 1981).

AQUIFER SYSTEMS AND HYDROGEOLOGIC CHARACTERISTICS

Ground water for municipal, industrial, rural domestic, and irrigation uses in the Treasure Valley is drawn almost entirely from Snake River Group and Idaho Group aquifers. Many domestic wells draw water from shallow aquifers, such as those in the Snake River Group deposits. Larger production wells (for municipal and agricultural uses) draw water from the deeper Idaho Group sediments.

Aquifers contained in the Snake River and Idaho Group sediments comprise shallow and regional ground water flow systems. Shallow aquifers contained in Snake River Group sediments and basalts may belong to local flow systems. Most local flow system recharge stems from irrigation infiltration and channel (e.g., streams or canals) losses. Discharge from shallow, local flow systems often is to local drains or streams. The time from recharge to discharge in shallow flow systems (residence times) probably ranges from days to tens of years.

In contrast, regional ground water flow systems extend much deeper than local flow systems. The Treasure Valley regional flow system begins in the eastern part of the valley, as indicated by downward hydraulic gradients in the Boise Fan sediments described by (Squires et al., 1992). Some water also enters the regional flow system as underflow from the Boise Foothills in the northeastern part of the valley. The regional flow system is thought to discharge primarily to the Boise and Snake Rivers in the western and southwestern parts of the valley.

Aquifer material characteristics, material heterogeneity, and structural controls influence Treasure Valley ground water flow. Coarse-grained materials (e.g., sand and gravel) in upper zones are more capable of transmitting ground water than fine-grained sediments (e.g., silt and clay). Clay and silt in the Snake River sediments can restrict vertical and/or horizontal ground water movement. Perched aquifers are created when fine-grained lenses impede downward vertical flow. A distinctive clay layer, sometimes referred to as "blue clay," is present over large portions of the valley. The clay is absent in the easternmost portions of the lower Boise River Basin, but can reach a thickness of more than 200 feet toward the central and western portions of the basin.

Sequences of interbedded sand, silt, and clay, such as the Deer Flat Surface and the upper portion of the Glens Ferry Formation of the upper Idaho Group in the Parma-Caldwell area, are the major water-producing aquifers in a large part of Canyon County (Anderson and Wood, 1981). The coarse-grained sediments in this zone produce water in excess of 2,000 gallons per minute (gpm).

The delineated source water assessment areas for the City of Parma can best be described as northeast trending corridors approximately 2 miles long and ¼ mile wide (Appendix A, Figures 2 through 6). The actual data used by BARR Engineering in determining the source water assessment delineation areas are available from DEQ upon request.

Identifying Potential Sources of Contamination

A potential source of contamination is defined as any facility or activity that stores, uses, or produces, as a product or by-product, the contaminants regulated under the Safe Drinking Water Act and has a sufficient likelihood of releasing such contaminants at levels that could pose a concern relative to drinking water sources. The goal of the inventory process is to locate and describe those facilities, land uses, and environmental conditions that are potential sources of groundwater contamination. The locations of potential sources of contamination within the delineation areas were obtained by field surveys conducted by DEQ, the local operator, and from available databases.

Land use within the immediate area of the City of Parma wellheads consists of residential, commercial, and transportation corridor uses, while the surrounding area is predominantly irrigated agriculture.

It is important to understand that a release may never occur from a potential source of contamination provided they are using best management practices. Many potential sources of contamination are regulated at the federal level, state level, or both to reduce the risk of release. Therefore, when a business, facility, or property is identified as a potential contaminant source, this should not be interpreted to mean that this business, facility, or property is in violation of any local, state, or federal environmental law or regulation. What it does mean is that the potential for contamination exists due to the nature of the business, industry, or operation. There are a number of methods that water systems can use to work cooperatively with potential sources of contamination, including educational visits and inspections of stored materials. Many owners of such facilities may not even be aware that they are located near a public water supply well.

Contaminant Source Inventory Process

A two-phased contaminant inventory of the study area was conducted in September and October 2001. The first phase involved identifying and documenting potential contaminant sources within the City of Parma source water assessment areas (Appendix A, Figures 2 through 11) through the use of computer databases and Geographic Information System maps developed by DEQ. The second, or enhanced, phase of the contaminant inventory involved contacting the operator to identify and add any additional potential sources in the area.

The delineated source water areas contain a varying number of potential contaminant sites, ranging from zero (Well #10) to 10 (Well #7). The delineations contain a major transportation corridor (Highway 20/26), underground storage tank (UST) sites, leaking underground storage tank (LUST) sites, and various commercial and agricultural sources as potential sources of contamination. Spills occurring on the transportation corridors could contribute all classes of contamination to the aquifer. Appendix A contains the locations of these potential contaminant sources as well as a description for each well (Tables A-1 through A-4).

Section 3. Susceptibility Analyses

Each well's susceptibility to contamination was ranked as high, moderate, or low risk according to the following considerations: hydrologic characteristics, physical integrity of the well, land use characteristics, and potentially significant contaminant sources. The susceptibility rankings are specific to a particular potential contaminant or category of contaminants. Therefore, a high susceptibility rating relative to one potential contaminant does not mean that the water system is at the same risk for all other potential contaminants. The relative ranking that is derived for each well is a qualitative, screening-level step that, in many cases, uses generalized assumptions and best professional judgement. Appendix A contains the susceptibility analysis worksheets. The following summaries describe the rationale for the susceptibility ranking.

Hydrologic Sensitivity

The hydrologic sensitivity of a well is dependent upon four factors: the surface soil composition, the material in the vadose zone (between the land surface and the water table), the depth to first ground water, and the presence of fine-grained geologic material above the producing zone of the well. Slowly

draining soils such as silt and clay typically are more protective of ground water than coarse-grained soils such as sand and gravel. Similarly, fine-grained sediments in the subsurface and a water depth of more than 300 feet protect the ground water from contamination.

Hydrologic sensitivity is moderate for Wells #6, #9, and #10, and high for Wells #7 and #8 (Table 2). Lack of a lithologic log caused Well #7 to be rated as high sensitivity. Well #8 does not have the requisite 50 feet of low permeability layers above the producing zone of the well. Regional soil data indicate the presence of moderately to well drained soils in the area of the delineations. Low permeability layers with greater than 50 feet cumulative thicknesses are documented for Wells #6, #9, and #10. The vadose zone near the wellheads consists of top soil, sand, silt, and clay in various proportions. The water table is located between 7 feet and 65 feet of the ground surface.

Well Construction

Well construction directly affects the ability of the well to protect the aquifer from contaminants. System construction scores are reduced when information shows that potential contaminants will have a more difficult time reaching the intake of the well. Lower scores imply a system is less vulnerable to contamination. For example, if the well casing and annular seal both extend into a low permeability unit, then the possibility of contamination is reduced and the system construction score goes down. If the highest production interval is more than 100 feet below the water table, then the system is considered to have better buffering capacity. Well driller's reports were available for all the wells except Well #7. The information about the wells is summarized below (Table 1). If the well is protected from surface flooding and is outside the 100-year floodplain, then contamination from surface events is reduced. A sanitary survey of the various well sites indicates that all the wells have adequate well houses to protect them from surface flooding, as well as protective surface and well seals, except for Well #7, which could not be assessed. GWUDI field surveys conducted in 1997 show the location of contaminant sources within 50 feet of the wellheads. Wells #6, #9, and #10 rate low for system construction, Well #8 rates moderate, and Well #7 rates high for system construction.

Table 1. City of Parma Well Construction Summary Information

Well	Well Depth (ft)	Static Water Depth (ft)	Casing: diameter/ thickness (in)	Casing: depth (ft)/ formation	Surface seal: depth (ft)/ formation	Screened Interval (ft)	Drill Year	Sanitary Survey Elements (A/B) ¹
Well #6	310	47	20, 16, 12/0.375	310/Blue clay	20/Sandy clay	178-203, 218-258, 260-300	1978	Yes/Yes
Well #7	400	23	NI/NI	NI/NI	NI/NI	NI	1980	NI/Yes
Well #8	200	7	12/0.375, 10/0.305, 8/0.250, 6/0.250	178/Cemented sand	22/Sand and gravel	142-147, 152-163, 163-178	1984	Yes/Yes
Well #9	306	47	12/0.375, 8&6/0.250	250/Dirty blue sand	28/Topsoil, silty sand, tree roots	172-187, 193.5-199	1984	Yes/Yes
Well #10	505	63	16/NI, 8/NI	485/Fine blue sand & Pea gravel	220/Blue sandy clay	245-255, 268-273, 364-374, 454-459, 472-477	1988	Yes/Yes

¹ A = Well and surface seal in compliance; B = Protected from surface flooding; NI = no information was available

The well logs allowed a determination as to whether current public water system (PWS) construction standards are being met. Though the wells may have been in compliance with standards when they were completed, current PWS well construction standards are more stringent. The Idaho Department of Water Resources *Well Construction Standards Rules* (1993) require all PWSs to follow DEQ standards as well. IDAPA 58.01.08.550 requires that PWSs follow the *Recommended Standards for Water Works* (1997) during construction. Some of the regulations deal with screening requirements, aquifer pump tests, surface seal placement, and thickness of casing. Table 1 of the *Recommended Standards for Water Works* (1997) lists the required steel casing thickness for various diameter wells. Ten-inch casing requires 0.365-inch thick casing, and 12-inch and larger casing requires a casing thickness of at least 0.375-inches. Therefore, all the wells, except for Well #6 were assessed an additional point in the system construction rating.

Potential Contaminant Source and Land Use

All the wells have a moderate land use score for IOCs (i.e. nitrates, arsenic), VOCs (i.e. petroleum products), and SOC's (i.e. pesticides, plasticizers), and a low land use score for microbial contamination (i.e. bacteria), except for Well #9 which has a low VOC land use rating (Table 2). Commercial, agricultural, and a transportation corridor within the delineated source areas account for the largest contribution of points to the potential contaminant inventory ratings. Surrounding agricultural land use practices have contributed to putting all the wells within areas rated "high" for county level nitrogen fertilizer use, county level herbicide use, and total county level ag-chemical use.

Final Susceptibility Ranking

A detection above a drinking water standard MCL, any detection of a VOC or SOC, or a detection of total coliform bacteria or fecal coliform bacteria at the wellhead will automatically give a high susceptibility rating to a well despite the land use of the area because a pathway for contamination already exists. Additionally, storing potential contaminant sources within 50 feet of a wellhead will automatically lead to a high susceptibility rating. In this case, Well #7 automatically rated high for SOC's because of the November 1998 detection of Di(2-ethylhexyl)phthalate in the tested water. Well #8 automatically rates high for all types of contamination because of a major transportation corridor (Highway 20/26) within 50 feet of the wellhead. Hydrologic sensitivity and system construction scores are heavily weighted in the final scores. Having multiple potential contaminant sources in the 0- to 3-year time of travel zone (Zone 1B) and agricultural land contribute greatly to the overall ranking. In terms of total susceptibility, except as noted above, the wells generally rated moderate for all categories, though Well #7 rated high for all categories due to a lack of information, and Well #6 rated low for VOCs and microbial contamination.

Table 2. Summary of City of Parma Susceptibility Evaluation

Well	Susceptibility Scores ¹									
	Hydrologic Sensitivity	Contaminant Inventory				System Construction	Final Susceptibility Ranking			
		IOC	VOC	SOC	Microbial s		IOC	VOC	SOC	Microbials
Well #6	M	M	M	M	L	L	M	L	M	L
Well #7	H	M	M	M	L	H	H	H	H(*) ²	H
Well #8	H	M	M	M	L	M	H* ³	H*	H*	H*
Well #9	M	M	M	M	L	L	M	M	M	M
Well #10	M	M	L	M	L	L	M	M	M	M

¹H = High Susceptibility, M = Moderate Susceptibility, L = Low Susceptibility,

IOC = inorganic chemical, VOC = volatile organic chemical, SOC = synthetic organic chemical

²H(*) = Well scored high and automatically high due to detection of Di(2-ethylhexyl)phthalate in tested water

³H* = well scored automatically high due to prsence of Highway 20/26 within 50 feet of the wellhead

Susceptibility Summary

In terms of total susceptibility, except as noted above, the wells generally rated moderate for all categories, though Well #7 rated high for all categories due to a lack of information, and Well #6 rated low for VOCs and microbial contamination. Well #7 automatically rated high for SOC because of the November 1998 detection of Di(2-ethylhexyl)phthalate in the tested water. Well #8 automatically rates high for all types of contamination because of a major transportation corridor (Highway 20/26) within 50 feet of the wellhead.

The most recent, significant water chemistry issue is the November 1998 Well #7 detection of the SOC Di(2-ethylhexyl)phthalate at a level of 5.62 ppb, where the MCL is 6.0 ppb. There have also been detections in the tested well water of the IOCs fluoride, arsenic, and nitrate at levels below the current MCLs as set by the EPA. Total coliform bacteria were detected in the distribution system in November 1992 and October 2000. Additionally, the VOC chloroform, a by-product of disinfection, was detected in all the wells. Other than Well #7, no SOC's have been detected in the well water. Surrounding agricultural land use practices have contributed to putting all the wells within areas rated "high" for county level nitrogen fertilizer use, county level herbicide use, and total county level ag-chemical use.

Section 4. Options for Drinking Water Protection

The susceptibility assessment should be used as a basis for determining appropriate new protection measures or re-evaluating existing protection efforts. No matter what the susceptibility ranking a source receives, protection is always important. Whether the source is currently located in a "pristine" area or an area with numerous industrial and/or agricultural land uses that require surveillance, the way to ensure good water quality in the future is to act now to protect valuable water supply resources.

An effective drinking water protection program is tailored to the particular local drinking water protection area. A community with a fully developed source water protection program will incorporate many strategies. For the City of Parma, drinking water protection activities should first focus on maintaining the maintenance of the well seal, sanitary seal, and flood protection, as documented on

sanitary surveys. As many of the delineations cover predominantly urban areas, there should be a strong public education program to make people aware that they live above their source of drinking water. Storm water practices should also be assessed. Public education topics could include proper lawn and garden care practices, household hazardous waste disposal methods, proper care and maintenance of septic systems, and the importance of water conservation to name but a few.

Additionally, since some of the well delineations cross agricultural land uses, there should be a focus on implementation of practices aimed at reducing the leaching of agricultural chemicals from agricultural land within the designated source water areas. No potential contaminants sources are allowed within 50 feet of any of the wellheads (IDAPA 58.01.08). Actions should be taken to protect the 50-foot boundary around Wells #7 and #8. Since it may be impractical to move Highway 20/26, a contingency plan should be set up to remove Well #8 from the system in the unlikely event a spill should occur near to the well. Much of the designated protection areas are outside the direct jurisdiction of the City of Parma, making collaboration and partnerships with state and local agencies and industry groups critical to the success of drinking water protection. All wells should maintain sanitary standards regarding wellhead protection. Should microbial contamination become a problem, appropriate disinfection practices would need to be implemented in a way to protect the drinking water from VOC by-products of the practice.

Due to the time involved with the movement of ground water, drinking water protection activities should be aimed at long-term management strategies even though these strategies may not yield results in the near term. A strong public education program should be a primary focus of any drinking water protection plan as the delineations contain some urban and residential land uses. There are multiple resources available to help communities implement protection programs, including the Drinking Water Academy of the U.S. Environmental Protection Agency. As there are transportation corridors through the delineations, the Idaho Department of Transportation should be involved in protection activities. Drinking water protection activities for agriculture should be coordinated with the Idaho State Department of Agriculture, the Soil Conservation Commission, the local Soil Conservation District, and the Natural Resources Conservation Service.

A community must incorporate a variety of strategies in order to develop a comprehensive drinking water assessment protection plan, be they regulatory in nature (i.e. zoning, permitting) or non-regulatory in nature (i.e. good housekeeping, public education, specific best management practices). For assistance in developing protection strategies please contact the Boise Regional Office of the Idaho Department of Environmental Quality or the Idaho Rural Water Association.

If the system should need to expand in the future, new well sites should be located in areas with as few potential sources of contamination as possible, and the site should be reserved and protected for this specific use. Any new wells that are installed as PWSs are required to follow current well construction standards. The Idaho Department of Water Resources *Well Construction Standards Rules* (1993) require all PWSs to follow DEQ standards as well. IDAPA 58.01.08.550 requires that PWSs follow the *Recommended Standards for Water Works* (1997) during construction.

Assistance

Public water supplies and others may call the following DEQ offices with questions about this assessment and to request assistance with developing and implementing a local protection plan. In addition, draft protection plans may be submitted to the DEQ office for preliminary review and comments.

Boise Regional DEQ Office (208) 373-0550

State DEQ Office (208) 373-0502

Website: <http://www.deq.state.id.us>

Water suppliers serving fewer than 10,000 persons may contact Melinda Harper, Idaho Rural Water Association, at (208) 373-7001 (mharper@idahoruralwater.com) for assistance with drinking water protection (formerly wellhead protection) strategies.

POTENTIAL CONTAMINANT INVENTORY LIST OF ACRONYMS AND DEFINITIONS

AST (Aboveground Storage Tanks) – Sites with aboveground storage tanks.

Business Mailing List – This list contains potential contaminant sites identified through a yellow pages database search of standard industry codes (SIC).

CERCLIS – This includes sites considered for listing under the **Comprehensive Environmental Response Compensation and Liability Act (CERCLA)**. CERCLA, more commonly known as ASuperfund, is designed to clean up hazardous waste sites that are on the national priority list (NPL).

Cyanide Site – DEQ permitted and known historical sites/facilities using cyanide.

Dairy – Sites included in the primary contaminant source inventory represent those facilities regulated by Idaho State Department of Agriculture (ISDA) and may range from a few head to several thousand head of milking cows.

Deep Injection Well – Injection wells regulated under the Idaho Department of Water Resources generally for the disposal of stormwater runoff or agricultural field drainage.

Enhanced Inventory – Enhanced inventory locations are potential contaminant source sites added by the water system. These can include new sites not captured during the primary contaminant inventory, or corrected locations for sites not properly located during the primary contaminant inventory. Enhanced inventory sites can also include miscellaneous sites added by the Idaho Department of Environmental Quality (DEQ) during the primary contaminant inventory.

Floodplain – This is a coverage of the 100-year floodplains.

Group 1 Sites – These are sites that show elevated levels of contaminants and are not within the priority one areas.

Inorganic Priority Area – Priority one areas where greater than 25% of the wells/springs show constituents higher than primary standards or other health standards.

Landfill – Areas of open and closed municipal and non-municipal landfills.

LUST (Leaking Underground Storage Tank) – Potential contaminant source sites associated with leaking underground storage tanks as regulated under RCRA.

Mines and Quarries – Mines and quarries permitted through the Idaho Department of Lands.)

Nitrate Priority Area – Area where greater than 25% of wells/springs show nitrate values above 5mg/l.

NPDES (National Pollutant Discharge Elimination System) – Sites with NPDES permits. The Clean Water Act requires that any discharge of a pollutant to waters of the United States from a point source must be authorized by an NPDES permit.

Organic Priority Areas – These are any areas where greater than 25 % of wells/springs show levels greater than 1% of the primary standard or other health standards.

Recharge Point – This includes active, proposed, and possible recharge sites on the Snake River Plain.

RICRIS – Site regulated under **Resource Conservation Recovery Act (RCRA)**. RCRA is commonly associated with the cradle to grave management approach for generation, storage, and disposal of hazardous wastes.

SARA Tier II (Superfund Amendments and Reauthorization Act Tier II Facilities) – These sites store certain types and amounts of hazardous materials and must be identified under the Community Right to Know Act.

Toxic Release Inventory (TRI) – The toxic release inventory list was developed as part of the Emergency Planning and Community Right to Know (Community Right to Know) Act passed in 1986. The Community Right to Know Act requires the reporting of any release of a chemical found on the TRI list.

UST (Underground Storage Tank) – Potential contaminant source sites associated with underground storage tanks regulated as regulated under RCRA.

Wastewater Land Applications Sites – These are areas where the land application of municipal or industrial wastewater is permitted by DEQ.

Wellheads – These are drinking water well locations regulated under the Safe Drinking Water Act. They are not treated as potential contaminant sources.

NOTE: Many of the potential contaminant sources were located using a geocoding program where mailing addresses are used to locate a facility. Field verification of potential contaminant sources is an important element of an enhanced inventory.

Where possible, a list of potential contaminant sites unable to be located with geocoding will be provided to water systems to determine if the potential contaminant sources are located within the source water assessment area.

References Cited


- Anderson, J.E. and Wood, S.H., 1981. Geological, Hydrological Geochemical and Geophysical Investigations of the Parma-Caldwell and Adjacent Areas, Southwestern Idaho. Chapter 3, Geohydrology, In: Mitchell, J. C., ed., Geothermal Investigations in Idaho, Part 11: Idaho Department of Water Resources, Water Information Bulletin 30: p. 33-42.
- Clemens, D.M., 1993. Volcanic stratigraphy and tectonic development, Western Snake River Plain, Idaho. M.S. Thesis, Arizona State University.
- Great Lakes-Upper Mississippi River Board of State and Provincial Public Health and Environmental Managers, 1997. "Recommended Standards for Water Works."
- Idaho Department of Agriculture, 1998. Unpublished Data.
- Idaho Department of Environmental Quality, 1997. Design Standards for Public Drinking Water Systems. IDAPA 58.01.08.550.01.
- Idaho Department of Water Resources, 1993. Administrative Rules of the Idaho Water Resource Board: Well Construction Standards Rules. IDAPA 37.03.09.
- Malde, H.E., 1991. Quaternary geology and structural history of the Snake River Plain, Idaho and Oregon. In: The Geology of North America, Quaternary Nonglacial Geology: Conterminous U.S., Vol. K-2, 252-281 pp.
- Malde, H.E. and Powers, H.A., 1962. Upper Cenozoic stratigraphy of Western Snake River Plain. Geological Society of America Bulletin, 73: 1197-1220.
- Neely, K.W. and J.K. Crockett, 1998. "Ground Water Quality Characterization and Initial Trend Analyses for the Treasure Valley Shallow and Deep Hydrogeologic Subareas," Idaho Department of Water Resources, Water Information Bulletin No. 50, Part 3.
- Othberg, K.L., 1994. Geology and geomorphology of the Boise Valley and adjoining areas, western Snake River Plain, Idaho. Idaho Geological Survey Bulletin 29: 54 pp.
- Othberg, K.L. and Stanford, L., 1992. Geologic map of the Boise Valley and adjoining area, Western Snake River Plain, Idaho. Idaho Geological Survey.
- Petrich, C.R. and S.M. Urban, 1996. "Treasure Valley Hydrologic Project Background – Draft," September, 1996.
- Petrich, C.R. and J.H. Hutchings (IWRRI), S.M. Urban and R.A. Carlson (IDWR), 1999. "Progress Report on the Characterization of Treasure Valley Ground Water Resources – Draft," prepared for and in cooperation with the Idaho Department of Water Resources, June 30, 1999.

- Squires, E., Wood, S.H. and Osiensky, J.L., 1992. Hydrogeologic Framework of the Boise Aquifer System, Ada County, Idaho, Research Technical Completion Report, Idaho Water Resources Research Institute, University of Idaho. 114 pp.
- Wood, S.H., 1994. Seismic expression and geological significance of a lacustrine delta in Neogene deposits of the Western Snake River Plain, Idaho. AAPG Bulletin, 1(January): p. 102-121.
- Wood, S.H. and Anderson, J.E., 1981. Part 11: Geological, hydrological, and geochemical and Geophysical investigations of the Parma-Caldwell and adjacent areas, southwestern Idaho. In: J.C. Mitchell (Editor), Geothermal investigations in Idaho. Idaho Department of Water Resources.
- Wuolo, R.W., J. Wittman, and D.M. Reynolds, 2001. "Summary Report: Delineation of Public Drinking Water Sources for the Source Water Assessment Program: Boise Valley and Mountain Home Plateau," BARR, Minneapolis, August 2001.

Appendix A

Delineation Figures and Potential Contaminant Tables

Figure 2. City of Parma Delineation Map and Potential Contaminant Source Locations




0 0.5 1 Miles



PWS# 3140089
WELL #6

Figure 3. City of Parma Delineation Map and Potential Contaminant Source Locations




0 0.5 1 Miles



PWS# 3140089
WELL #7

Figure 4. City of Parma Delineation Map and Potential Contaminant Source Locations



0 0.5 1 Miles



PWS# 3140089
WELL #8

Table A-1. Well #6, Potential Contaminant Inventory

Site #	Source Description ¹	TOT ZONE ²	Source of Information	Potential Contaminants ³
1	UST - closed	0-3	Database Search	VOC, SOC

¹ UST = underground storage tank² TOT = time-of-travel (in years) for a potential contaminant to reach the wellhead³ IOC = inorganic chemical, VOC = volatile organic chemical, SOC = synthetic organic chemical**Table A-2. Well #7, Potential Contaminant Inventory**

Site #	Source Description ¹	TOT ZONE ²	Source of Information	Potential Contaminants ³
1, 5	LUST – Site Cleanup Incomplete, Impact: GROUND WATER: UST – Closed	0-3	Database Search	VOC, SOC
2	LUST – Site Cleanup Incomplete, Impact: GROUND WATER	0-3	Database Search	IOC, VOC, SOC
3	UST – Open	0-3	Database Search	VOC, SOC
4	UST – Closed	0-3	Database Search	VOC, SOC
6, 7	Farm Equipment Manufacturers (Wholesale)	0-3	Database Search	IOC, VOC, SOC
8	Farm Equipment Manufacturers	0-3	Database Search	IOC, VOC, SOC
	Highway 20/26	0-3	GIS Map	IOC, VOC, SOC, Microbes

¹ UST = underground storage tank, LUST = leaking underground storage tank² TOT = time-of-travel (in years) for a potential contaminant to reach the wellhead; 1A = within 50 feet³ IOC = inorganic chemical, VOC = volatile organic chemical, SOC = synthetic organic chemical**Table A-3. Well #8, Potential Contaminant Inventory**


Site #	Source Description ¹	TOT ZONE ²	Source of Information	Potential Contaminants ³
1	UST – Closed	0-3	Database Search	VOC, SOC
	Highway 20/26	0-3 (1A)	GIS Map	IOC, VOC, SOC, Microbes

² TOT = time-of-travel (in years) for a potential contaminant to reach the wellhead; 1A = within 50 feet³ IOC = inorganic chemical, VOC = volatile organic chemical, SOC = synthetic organic chemical**Table A-4. Well #9, Potential Contaminant Inventory**

Site #	Source Description ¹	TOT ZONE ²	Source of Information	Potential Contaminants ³
1	UST - closed	0-3	Database Search	VOC, SOC

¹ UST = underground storage tank² TOT = time-of-travel (in years) for a potential contaminant to reach the wellhead³ IOC = inorganic chemical, VOC = volatile organic chemical, SOC = synthetic organic chemical

Figure 5. City of Parma Delineation Map and Potential Contaminant Source Locations




0 0.5 1 Miles



PWS# 3140089
WELL #9

Figure 6. City of Parma Delineation Map and Potential Contaminant Source Locations



0 0.5 1 Miles



PWS# 3140089
WELL #10

Appendix B

City of Parma
Susceptibility Analysis
Worksheets

The final scores for the susceptibility analysis were determined using the following formulas:

- 1) VOC/SOC/IOC Final Score = Hydrologic Sensitivity + System Construction + (Potential Contaminant/Land Use x 0.2)
- 2) Microbial Final Score = Hydrologic Sensitivity + System Construction + (Potential Contaminant/Land Use x 0.35)

Final Susceptibility Scoring:

0 - 5 Low Susceptibility

6 - 12 Moderate Susceptibility

≥ 13 High Susceptibility

1. System Construction		SCORE			
Drill Date	12/04/1978				
Driller Log Available	YES				
Sanitary Survey (if yes, indicate date of last survey)	YES	1997			
Well meets IDWR construction standards	YES	0			
Wellhead and surface seal maintained	YES	0			
Casing and annular seal extend to low permeability unit	YES	0			
Highest production 100 feet below static water level	YES	0			
Well located outside the 100 year flood plain	YES	0			
Total System Construction Score		0			
2. Hydrologic Sensitivity					
Soils are poorly to moderately drained	NO	2			
Vadose zone composed of gravel, fractured rock or unknown	NO	0			
Depth to first water > 300 feet	NO	1			
Aquitard present with > 50 feet cumulative thickness	YES	0			
Total Hydrologic Score		3			
3. Potential Contaminant / Land Use - ZONE 1A		IOC Score	VOC Score	SOC Score	Microbial Score
Land Use Zone 1A	IRRIGATED CROPLAND	2	2	2	2
Farm chemical use high	YES	2	0	2	
IOC, VOC, SOC, or Microbial sources in Zone 1A	NO	NO	NO	NO	NO
Total Potential Contaminant Source/Land Use Score - Zone 1A		4	2	4	2
Potential Contaminant / Land Use - ZONE 1B					
Contaminant sources present (Number of Sources)	YES	0	1	1	0
(Score = # Sources X 2) 8 Points Maximum		0	2	2	0
Sources of Class II or III leacheable contaminants or	YES	4	1	0	
4 Points Maximum		4	1	0	
Zone 1B contains or intercepts a Group 1 Area	NO	0	0	0	0
Land use Zone 1B Greater Than 50% Irrigated Agricultural Land		4	4	4	4
Total Potential Contaminant Source / Land Use Score - Zone 1B		8	7	6	4
Potential Contaminant / Land Use - ZONE II					
Contaminant Sources Present	NO	0	0	0	
Sources of Class II or III leacheable contaminants or	YES	1	0	0	
Land Use Zone II Greater Than 50% Irrigated Agricultural Land		2	2	2	
Potential Contaminant Source / Land Use Score - Zone II		3	2	2	0
Potential Contaminant / Land Use - ZONE III					
Contaminant Source Present	NO	0	0	0	
Sources of Class II or III leacheable contaminants or	YES	1	0	0	
Is there irrigated agricultural lands that occupy > 50% of	YES	1	1	1	
Total Potential Contaminant Source / Land Use Score - Zone III		2	1	1	0
Cumulative Potential Contaminant / Land Use Score		17	12	13	6
4. Final Susceptibility Source Score		6	5	6	5
5. Final Well Ranking		Moderate	Low	Moderate	Low

1. System Construction		SCORE			
Drill Date	03/26/1980				
Driller Log Available	YES				
Sanitary Survey (if yes, indicate date of last survey)	YES	1997			
Well meets IDWR construction standards	NO	1			
Wellhead and surface seal maintained	NO	1			
Casing and annular seal extend to low permeability unit	NO	2			
Highest production 100 feet below static water level	NO	1			
Well located outside the 100 year flood plain	YES	0			
Total System Construction Score		5			
2. Hydrologic Sensitivity					
Soils are poorly to moderately drained	NO	2			
Vadose zone composed of gravel, fractured rock or unknown	YES	1			
Depth to first water > 300 feet	NO	1			
Aquitard present with > 50 feet cumulative thickness	NO	2			
Total Hydrologic Score		6			
3. Potential Contaminant / Land Use - ZONE 1A		IOC Score	VOC Score	SOC Score	Microbial Score
Land Use Zone 1A	IRRIGATED CROPLAND	2	2	2	2
Farm chemical use high	YES	2	0	2	
IOC, VOC, SOC, or Microbial sources in Zone 1A	YES	NO	NO	YES	NO
Total Potential Contaminant Source/Land Use Score - Zone 1A		4	2	4	2
Potential Contaminant / Land Use - ZONE 1B					
Contaminant sources present (Number of Sources)	YES	3	7	7	1
(Score = # Sources X 2) 8 Points Maximum		6	8	8	2
Sources of Class II or III leacheable contaminants or	YES	3	5	1	
4 Points Maximum		3	4	1	
Zone 1B contains or intercepts a Group 1 Area	NO	0	0	0	0
Land use Zone 1B	25 to 50% Irrigated Agricultural Land	2	2	2	2
Total Potential Contaminant Source / Land Use Score - Zone 1B		11	14	11	4
Potential Contaminant / Land Use - ZONE II					
Contaminant Sources Present	NO	0	0	0	
Sources of Class II or III leacheable contaminants or	YES	1	0	0	
Land Use Zone II	Greater Than 50% Irrigated Agricultural Land	2	2	2	
Potential Contaminant Source / Land Use Score - Zone II		3	2	2	0
Potential Contaminant / Land Use - ZONE III					
Contaminant Source Present	NO	0	0	0	
Sources of Class II or III leacheable contaminants or	YES	1	0	0	
Is there irrigated agricultural lands that occupy > 50% of	YES	1	1	1	
Total Potential Contaminant Source / Land Use Score - Zone III		2	1	1	0
Cumulative Potential Contaminant / Land Use Score		20	19	18	6
4. Final Susceptibility Source Score		15	15	15	13
5. Final Well Ranking		High	High	High	High

1. System Construction		SCORE				
Drill Date		07/12/1984				
Driller Log Available		YES				
Sanitary Survey (if yes, indicate date of last survey)		YES 1997				
Well meets IDWR construction standards		NO 1				
Wellhead and surface seal maintained		YES 0				
Casing and annular seal extend to low permeability unit		NO 2				
Highest production 100 feet below static water level		YES 0				
Well located outside the 100 year flood plain		YES 0				
Total System Construction Score		3				
2. Hydrologic Sensitivity						
Soils are poorly to moderately drained		NO 2				
Vadose zone composed of gravel, fractured rock or unknown		NO 0				
Depth to first water > 300 feet		NO 1				
Aquitard present with > 50 feet cumulative thickness		NO 2				
Total Hydrologic Score		5				
3. Potential Contaminant / Land Use - ZONE 1A		IOC Score	VOC Score	SOC Score	Microbial Score	
Land Use Zone 1A		IRRIGATED CROPLAND	2	2	2	2
Farm chemical use high		YES	2	0	2	
IOC, VOC, SOC, or Microbial sources in Zone 1A		YES	YES	YES	YES	YES
Total Potential Contaminant Source/Land Use Score - Zone 1A		4	2	4	2	
Potential Contaminant / Land Use - ZONE 1B						
Contaminant sources present (Number of Sources)		YES	1	2	2	1
(Score = # Sources X 2) 8 Points Maximum			2	4	4	2
Sources of Class II or III leacheable contaminants or		YES	5	2	1	
4 Points Maximum			4	2	1	
Zone 1B contains or intercepts a Group 1 Area		NO	0	0	0	0
Land use Zone 1B Greater Than 50% Irrigated Agricultural Land			4	4	4	4
Total Potential Contaminant Source / Land Use Score - Zone 1B		10	10	9	6	
Potential Contaminant / Land Use - ZONE II						
Contaminant Sources Present		NO	0	0	0	
Sources of Class II or III leacheable contaminants or		YES	1	0	0	
Land Use Zone II Greater Than 50% Irrigated Agricultural Land			2	2	2	
Potential Contaminant Source / Land Use Score - Zone II		3	2	2	0	
Potential Contaminant / Land Use - ZONE III						
Contaminant Source Present		NO	0	0	0	
Sources of Class II or III leacheable contaminants or		YES	1	0	0	
Is there irrigated agricultural lands that occupy > 50% of		YES	1	1	1	
Total Potential Contaminant Source / Land Use Score - Zone III		2	1	1	0	
Cumulative Potential Contaminant / Land Use Score		19	15	16	8	
4. Final Susceptibility Source Score		12	11	11	11	
5. Final Well Ranking		High	High	High	High	

1. System Construction		SCORE			
Drill Date	08/25/1984				
Driller Log Available	YES				
Sanitary Survey (if yes, indicate date of last survey)	YES	1997			
Well meets IDWR construction standards	NO	1			
Wellhead and surface seal maintained	YES	0			
Casing and annular seal extend to low permeability unit	YES	0			
Highest production 100 feet below static water level	YES	0			
Well located outside the 100 year flood plain	YES	0			
Total System Construction Score		1			
2. Hydrologic Sensitivity					
Soils are poorly to moderately drained	NO	2			
Vadose zone composed of gravel, fractured rock or unknown	NO	0			
Depth to first water > 300 feet	NO	1			
Aquitard present with > 50 feet cumulative thickness	YES	0			
Total Hydrologic Score		3			
3. Potential Contaminant / Land Use - ZONE 1A		IOC Score	VOC Score	SOC Score	Microbial Score
Land Use Zone 1A	IRRIGATED CROPLAND	2	2	2	2
Farm chemical use high	YES	2	0	2	
IOC, VOC, SOC, or Microbial sources in Zone 1A	NO	NO	NO	NO	NO
Total Potential Contaminant Source/Land Use Score - Zone 1A		4	2	4	2
Potential Contaminant / Land Use - ZONE 1B					
Contaminant sources present (Number of Sources)	YES	0	1	1	0
(Score = # Sources X 2) 8 Points Maximum		0	2	2	0
Sources of Class II or III leacheable contaminants or	YES	4	1	0	
4 Points Maximum		4	1	0	
Zone 1B contains or intercepts a Group 1 Area	NO	0	0	0	0
Land use Zone 1B Greater Than 50% Irrigated Agricultural Land		4	4	4	4
Total Potential Contaminant Source / Land Use Score - Zone 1B		8	7	6	4
Potential Contaminant / Land Use - ZONE II					
Contaminant Sources Present	NO	0	0	0	
Sources of Class II or III leacheable contaminants or	YES	1	0	0	
Land Use Zone II Greater Than 50% Irrigated Agricultural Land		2	2	2	
Potential Contaminant Source / Land Use Score - Zone II		3	2	2	0
Potential Contaminant / Land Use - ZONE III					
Contaminant Source Present	NO	0	0	0	
Sources of Class II or III leacheable contaminants or	YES	1	0	0	
Is there irrigated agricultural lands that occupy > 50% of	YES	1	1	1	
Total Potential Contaminant Source / Land Use Score - Zone III		2	1	1	0
Cumulative Potential Contaminant / Land Use Score		17	12	13	6
4. Final Susceptibility Source Score		7	6	7	6
5. Final Well Ranking		Moderate	Moderate	Moderate	Moderate

1. System Construction	SCORE			
Drill Date	11/03/1988			
Driller Log Available	YES			
Sanitary Survey (if yes, indicate date of last survey)	YES	1997		
Well meets IDWR construction standards	NO	1		
Wellhead and surface seal maintained	YES	0		
Casing and annular seal extend to low permeability unit	YES	0		
Highest production 100 feet below static water level	YES	0		
Well located outside the 100 year flood plain	YES	0		
Total System Construction Score		1		
2. Hydrologic Sensitivity				
Soils are poorly to moderately drained	NO	2		
Vadose zone composed of gravel, fractured rock or unknown	NO	0		
Depth to first water > 300 feet	NO	1		
Aquitard present with > 50 feet cumulative thickness	YES	0		
Total Hydrologic Score		3		
3. Potential Contaminant / Land Use - ZONE 1A		IOC Score	VOC Score	SOC Score
Land Use Zone 1A	IRRIGATED CROPLAND	2	2	2
Farm chemical use high	YES	2	0	2
IOC, VOC, SOC, or Microbial sources in Zone 1A	NO	NO	NO	NO
Total Potential Contaminant Source/Land Use Score - Zone 1A		4	2	4
Potential Contaminant / Land Use - ZONE 1B				
Contaminant sources present (Number of Sources)	NO	0	0	0
(Score = # Sources X 2) 8 Points Maximum		0	0	0
Sources of Class II or III leacheable contaminants or	YES	4	0	0
4 Points Maximum		4	0	0
Zone 1B contains or intercepts a Group 1 Area	NO	0	0	0
Land use Zone 1B Greater Than 50% Irrigated Agricultural Land		4	4	4
Total Potential Contaminant Source / Land Use Score - Zone 1B		8	4	4
Potential Contaminant / Land Use - ZONE II				
Contaminant Sources Present	NO	0	0	0
Sources of Class II or III leacheable contaminants or	YES	1	0	0
Land Use Zone II Greater Than 50% Irrigated Agricultural Land		2	2	2
Potential Contaminant Source / Land Use Score - Zone II		3	2	2
Potential Contaminant / Land Use - ZONE III				
Contaminant Source Present	NO	0	0	0
Sources of Class II or III leacheable contaminants or	YES	1	0	0
Is there irrigated agricultural lands that occupy > 50% of	YES	1	1	1
Total Potential Contaminant Source / Land Use Score - Zone III		2	1	1
Cumulative Potential Contaminant / Land Use Score		17	9	11
4. Final Susceptibility Source Score		7	6	6
5. Final Well Ranking		Moderate	Moderate	Moderate